

BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS

VAN AMBATIELOS  
PRESIDENT

E. FELICIA BRANNON  
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI  
MAYOR

DEPARTMENT OF  
BUILDING AND SAFETY

201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

FRANK BUSH  
GENERAL MANAGER

OSAMA YOUNAN, P.E.  
EXECUTIVE OFFICER

Doc's Industries, Inc.  
4121 Guardian St.  
Simi Valley, CA 93063

RESEARCH REPORT: RR 25654  
(CSI# 05 05 23)

BASED UPON ICC EVALUATION  
SERVICE REPORT NO. ESR-3135

Attn: Chad Dockery  
(805) 583-9911

REEVALUATION DUE  
DATE: July 01, 2021  
Issued Date: June 01, 2019  
Code: 2017 LABC

**GENERAL APPROVAL** – Reevaluation- I-LAG™ Brand Eye Lag Screws and Wire System.

**DETAILS**

The above assemblies and products are approved when in compliance with the description, use, identification and findings of Legacy Report No. ER-3135, reissued May 2017, revised September 2018, subject to renewal May 2019 of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

**The approval is subject to the following conditions:**

1. Allowable loads shall not be increased due to duration of load such as wind or earthquake.
2. Fasteners are embossed with four "I"s radiating from the shank on the top portion of the washer as shown in Figure 1. Each box of fasteners has a label bearing the I-LAG brand name, the manufacturer's name and address, the fastener type, the quantity and the ICC-ES report number (ESR-3135).
3. Fasteners are installed in accordance with the manufacturer's instructions and this report.
4. Calculations demonstrating that applied loads comply with this report shall be prepared by a licensed engineer or architect registered in the State of California.

RR 25654  
Page 1 of 2

Doc's Industries, Inc.  
Re: I-LAG™ Brand Eye Lag Screws and Wire System

## **DISCUSSION**

The report is in compliance with 2017 Los Angeles Building Code.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction, which must be approved, by Department of Building and Safety Engineers and Inspectors.

---

DAVID CHANG, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone- 213-202-9814  
Fax- 213-202-9943

BKR  
RR25654  
R05-20-2019  
TLB11900103  
2304.10

Attached: ICC-ES Evaluation Legacy Report No. ESR-3135 (3 Pages)